



MARYSVILLE FIRE DISTRICT
REGIONAL FIRE AUTHORITY
Fire Marshal's Office
1635 Grove St. Marysville, WA 98270 - (360) 363-8500
MFInspectors@MFDRA.org - www.marysvillefiredistrict.org



To: Amy Hess, Senior Planner
From: Don McGhee, Assistant Fire Marshal
Date: November 16, 2023
Subject: Olympic Vista 13D Sprinkler Requirement

Hi Amy,
Cornerstone has completed a second access to the north on 59th Ave into the Olympic Vista Development.

- Homes under three stories no longer are required to have 13D sprinkler systems installed.
- All three story homes will still require 13D sprinklers to be installed.