



**MARYSVILLE**  
**PUBLIC WORKS**

**MEMORANDUM**

TO: Kathryn Bird, Associate Planner

FROM: Kim Bryant, Water Operations Supervisor  
Tim King, Utility Construction Lead II  
Ryan Keefe, Water Operations Lead II

DATE: February 24<sup>th</sup>, 2023

SUBJECT: Hsiao Short Plat 3<sup>rd</sup> Submittal, SP22004

Public Works Operations has reviewed the Hsiao Short Plat 3rd submittal and has the following comments:

1. 6" cap is called out at end of water main, needs to be changed to an 8" cap with blow off;
2. If water service for Lot 5 could be moved north to out of driveway that would be preferred.

If the applicant has any questions about these comments, I can be contacted at (360) 363-8163 or [kbryant@marysvillewa.gov](mailto:kbryant@marysvillewa.gov).

(360) 363-8100

Public Works  
80 Columbia Avenue  
Marysville, WA 98270