

STATE OF WASHINGTON DEPARTMENT OF ECOLOGY Northwest Region Office PO Box 330316, Shoreline, WA 98133-9716 • 206-594-0000

July 22, 2024

Chris Holland, Planning Manager Community Development Department City of Marysville 501 Delta Ave Marysville, WA 98270

Re: Undi Commerce Park File# PA22-008, Ecology SEPA# 202402935

Dear Chris Holland:

Thank you for the opportunity to provide comments on the State Environmental Policy Act (SEPA) mitigated determination of nonsignificance (MDNS) for the Undi Commerce Park project. Based on review of the checklist associated with this project, the Department of Ecology (Ecology) has the following comments:

Under RCW 90.03.350, a Dam Safety construction permit is required for those dams or ponds that can impound a volume of 10 acre-feet or more of water or other liquids above ground level. This also includes ponds that share a common berm which in combination the volume is 10 acre-feet or more. The Undi Commerce Park project references stormwater facilities as part of the project, if this includes impoundments that meet or exceeds the above referenced criteria, you will need to apply for a dam construction permit. To determine if a Dam Safety construction permit is required for your project, the applicant must submit a set of construction plans to:

WA Department of Ecology Dam Safety Office P.O. Box 47600 Olympia, WA 98504-7600

The construction permit application can be found by entering the following link into your search engine: <u>https://apps.ecology.wa.gov/publications/summarypages/ecy07038.html</u>.

Chris Holland July 22, 2024 Page 2

Thank you for considering these comments from Ecology. If you have any questions or would like to respond to these comments, please contact Ecology's Dam Safety Office at (360) 407-6872 or by email at <u>damsafety@ecy.wa.gov</u>.

Sincerely,

Kelli Price

Kelli Price SEPA Coordinator

Sent by email: Chris Holland, cholland@marysvillewa.gov