

EST.



1891

MARYSVILLE

WASHINGTON

COMMUNITY DEVELOPMENT DEPARTMENT
80 Columbia Avenue, Marysville, WA 98270
(360) 363-8100, (360) 651-5099 FAX

ELECTRICAL PLAN REVIEW SUBMITTAL GUIDE/CHECKLIST

Review Required for the Following Work:

- All exterior appliance installations including Photovoltaic Systems and generators on all types of occupancies.
- Multi-family structures over two dwelling units.
- New non-residential, multifamily or mixed-use building
- Existing or new commercial service alterations, generators, subpanels, transformers, feeders, or hazardous locations as defined by NEC Increase in load of 100 amps or more.
- Installing/altering a service or feeder rated 100 amps or more.
- Any installation or alteration in a space with health care, educational, and institutional occupancy categories as listed in WCEC 85.15.G (1).
- Replacing 60% or more of the lighting luminaries and increasing the lighting load.
- Work on electrical systems operating at over 600 volts.
- Installations as required by the Building Official for installations, which by their nature are complex, hazardous or pose unique design problems.

Note: Please contact the City's Electrical Division with any questions at 360-363-8100.